

8-0

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2022 / 1019

Dated: 15/09/2022

FIRE SAFETY CERTIFICATE

Certified that the St. Johns Convent Sr. Sec. School located at B-4659, Street No.112, Sant Nagar, Burari, Delhi-84 comprised of Ground & 04 upper floors owned/ occupied by St. Johns Convent Sr. Sec. School was issued Fire Safety Certificated vide this office letter no. F-6/DFS/MS/2018/School/WZ/1896 dated 14.08.2018. The premise was re-inspected by the officer concerned of this department on 06.09.2022 in the presence of Sh. Vikas Pant (Acadmic Incharge) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under Educational "Group B" with effect from 15/09/2022 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 15/09/2022 at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, St. Johns Convent Sr. Sec. School located at B-4659, Street No.112, Sant Nagar, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doiit fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms).
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

